



Installation	Item No.	Quiksit No.	Brooks No.
Parkway	CST-3	PV-10.6-7	TE-1550 Pay.
Side Walk	CST-4	PV-10.6-7 Riv. Mod.	TE-1550 Riv.Mod.
Light Traffic	CSST-5	PV-S10.6-7 Tfc	TE-1550Tfc.

Notes:

1. Enclosure to be furnished complete with grates, covers, tamper vents, and stainless steel bolts (20)
2. Covers shall be painted, after fabrication, with one coat of rustproof primer and one coat of aluminium paint.
3. Grates for sidewalk installation shall have flatted expanded metal (1/2" NO. 13 ga.), top covering welded in place prior to galvanizing.
4. ALL CST's shall be furnished with stainless steel, penta head cap screws for securing.

DRAWN:	UNDERGROUND STRUCTURES STANDARDS	UGS-750 PAGE 1 OF 1
CHECKED:	COMMENCIAL SUBSURFACE TRANSFORMER ENCLOSURE	
APPROVED:	(CST)	
DATE: 10/28/1999		